Colongra Power Station Monthly Summary Report July 2016

Licenced	Pollutant	Unit of	Monitorin	Mean	Max	100	Published	Comment
Monitoring		Measure	g	Hourly	Hourly	Percentile	Date	
Point Code			Frequency	Averag	Averag	limit		
LDPI	Nitrogen dioxide - diesel	mg/m3	Continuous		-	90.0	4/08/2016	
LDPI	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	4/08/2016	Normal operation did not exceed I hour during the month
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	4/08/2016	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	4/08/2016	Normal operation did not exceed I hour during the month
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	4/08/2016	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	4/08/2016	Normal operation did not exceed I hour during the month
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	4/08/2016	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	4/08/2016	Normal operation did not exceed I hour during the month

Correction Log

L	icenced	Pollutant	Unit of	Monitorin	Mean	Max	100	Published	Reason for Correction	
ľ	lonitoring		Measure	g	Hourly	Hourly	Percentile	Date		
F	oint Code			Frequency	Averag	Averag	limit			
					_	_				
Original Data										

Corrected Data