

Colongra Power Station Monthly Summary Report February 2017

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	8/03/2017	No diesel used during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	31.4	33.4	60.0	8/03/2017	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	8/03/2017	No diesel used during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	42.8	56.9	60.0	8/03/2017	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	56.0	56.0	90.0	8/03/2017	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	22.5	24.7	60.0	8/03/2017	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	52.2	52.2	90.0	8/03/2017	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	24.5	30.5	60.0	8/03/2017	

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data								
Corrected Data								