

Colongra Power Station Monthly Summary Report March 2017

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	58.0	61.0	90.0	8/03/2017	Annual emissions test result, 1 hour average of 58 mg/m3
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	38.0	40.0	60.0	8/03/2017	Annual emissions test result, 1 hour average of 38 mg/m3
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	49.0	54.0	90.0	8/03/2017	Annual emissions test result, 1 hour average of 49 mg/m3
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	44.0	46.0	60.0	8/03/2017	Annual emissions test result, 1 hour average of 44 mg/m3
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	67.0	71.0	90.0	8/03/2017	Annual emissions test result, 1 hour average of 67 mg/m3
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	22.0	23.0	60.0	8/03/2017	Annual emissions test result, 1 hour average of 22 mg/m3
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	75.0	76.0	90.0	8/03/2017	Annual emissions test result, 1 hour average of 75 mg/m3
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	41.0	45.0	60.0	8/03/2017	Annual emissions test result, 1 hour average of 41 mg/m3

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data								
Corrected Data								