

Colongra Power Station Monthly Summary Report February 2018

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	62.0	68.0	90.0	9/03/2018	Annual emissions test result, 1 hour average of 62 mg/m3
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	38.9	48.0	60.0	9/03/2018	Annual emissions test result, 1 hour average of 42 mg/m3
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	66.0	68.0	90.0	9/03/2018	Annual emissions test result, 1 hour average of 66 mg/m3
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	48.0	51.0	60.0	9/03/2018	Annual emissions test result, 1 hour average of 48 mg/m3
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	70.0	75.0	90.0	9/03/2018	Annual emissions test result, 1 hour average of 70 mg/m3
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	29.1	35.0	60.0	9/03/2018	Annual emissions test result, 1 hour average of 31 mg/m3
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	87.0	88.0	90.0	9/03/2018	Annual emissions test result, 1 hour average of 87 mg/m3
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	40.0	47.0	60.0	9/03/2018	Annual emissions test result, 1 hour average of 40 mg/m3

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data								
Corrected Data								