Colongra Power Station Monthly Summary Report March 2019

Licenced Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	I00 Percentile limit	Published Date	Comment
LDPI	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	8/04/2019	Normal operation did not exceed 1 hour during the month
LDPI	Nitrogen dioxide - gas	mg/m3	Continuous	0.0	0.0	60.0	8/04/2019	Normal operation did not exceed 1 hour during the month
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	8/04/2019	Normal operation did not exceed I hour during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	0.0	0.0	60.0	8/04/2019	Normal operation did not exceed I hour during the month
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	8/04/2019	Normal operation did not exceed I hour during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	0.0	0.0	60.0	8/04/2019	Normal operation did not exceed I hour during the month
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	8/04/2019	Normal operation did not exceed I hour during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	0.0	0.0	60.0	8/04/2019	Normal operation did not exceed 1 hour during the month

Correction Log

	Licenced	Pollutant	Unit of	Monitoring	Mean	Max	100	Published	Reason for Correction
	Monitoring		Measure	Frequency	Hourly	Hourly	Percentile	Date	
	Point Code				Average	Average	limit		
Ų									

Original Data

Corrected Data