

Colongra Power Station Monthly Summary Report April 2019

| Licensed Monitoring Point Code | Pollutant | Unit of Measure | Monitoring Frequency | Mean Hourly Average | Max Hourly Average | 100 Percentile limit | Published Date | Comment |
|--------------------------------|---------------------------|-----------------|----------------------|---------------------|--------------------|----------------------|----------------|--|
| LDP1 | Nitrogen dioxide - diesel | mg/m3 | Continuous | 56.0 | 58.0 | 90.0 | 10/05/2019 | Annual emissions test result, 1 hour average of 56 mg/m3 |
| LDP1 | Nitrogen dioxide - gas | mg/m3 | Continuous | 41.0 | 44.0 | 60.0 | 10/05/2019 | Annual emissions test result, 1 hour average of 41 mg/m3 |
| LDP2 | Nitrogen dioxide - diesel | mg/m3 | Continuous | 70.0 | 71.0 | 90.0 | 10/05/2019 | Annual emissions test result, 1 hour average of 70 mg/m3 |
| LDP2 | Nitrogen dioxide - gas | mg/m3 | Continuous | 31.0 | 33.0 | 60.0 | 10/05/2019 | Annual emissions test result, 1 hour average of 31 mg/m3 |
| LDP3 | Nitrogen dioxide - diesel | mg/m3 | Continuous | 66.0 | 68.0 | 90.0 | 10/05/2019 | Annual emissions test result, 1 hour average of 66 mg/m3 |
| LDP3 | Nitrogen dioxide - gas | mg/m3 | Continuous | 29.0 | 35.0 | 60.0 | 10/05/2019 | Annual emissions test result, 1 hour average of 29 mg/m3 |
| LDP4 | Nitrogen dioxide - diesel | mg/m3 | Continuous | 77.0 | 80.0 | 90.0 | 10/05/2019 | Annual emissions test result, 1 hour average of 77 mg/m3 |
| LDP4 | Nitrogen dioxide - gas | mg/m3 | Continuous | 35.0 | 41.0 | 60.0 | 10/05/2019 | Annual emissions test result, 1 hour average of 35 mg/m3 |

Correction Log

| Licensed Monitoring Point Code | Pollutant | Unit of Measure | Monitoring Frequency | Mean Hourly Average | Max Hourly Average | 100 Percentile limit | Published Date | Reason for Correction |
|--------------------------------|-----------|-----------------|----------------------|---------------------|--------------------|----------------------|----------------|-----------------------|
|--------------------------------|-----------|-----------------|----------------------|---------------------|--------------------|----------------------|----------------|-----------------------|

Original Data

Corrected Data