

Modification of Minister's Approval

Section 75W of the *Environmental Planning & Assessment Act 1979*

As delegate of the Minister for Planning under delegation executed on 10 November 2014, I approve the modification of the project application referred to in schedule 1, subject to the conditions in schedule 2.



Director, Infrastructure
DEPARTMENT OF PLANNING & ENVIRONMENT

Sydney

20

November 2014

SCHEDULE 1

Project Approval:

05_0195 granted by the Minister for Planning on 31 July 2006

For the following:

Colongra Gas-Fired Power Station, Doyalson

Modification:

(MP 05_0195 Mod 3): Modification of the Project Approval to allow an increase in the nitrogen oxide (NO_x) emission limit for natural gas.

SCHEDULE 2 CONDITIONS

SPECIFIC ENVIRONMENTAL CONDITIONS

Discharge Limits

1. Delete condition 2.8 and replace with the following:

2.8 *The Proponent shall design, construct, operate and maintain the project to ensure that for each turbine stack discharge point, the concentration of each pollutant listed in Table 2 is not exceeded when utilising the specified fuel. This condition only applies to the operation of the project, and to avoid any doubt, does not apply during start-up or shut-down.*

Table 2 - Maximum Allowable Discharge Concentration Limits (Air)

Pollutant	Fuel Type	100 Percentile limit (mgm ⁻³)	Reference conditions
Nitrogen dioxide (NO ₂) or nitric oxide (NO), or both (as NO ₂)	Natural Gas	60	dry, 273 K, 101.3 kPa, and 15 % O ₂
	Diesel	90	