

Colongra Power Station Monthly Summary Report May 2017

| Licensed Monitoring Point Code | Pollutant | Unit of Measure | Monitoring Frequency | Mean Hourly Average | Max Hourly Average | 100 Percentile limit | Published Date | Comment |
|--------------------------------|---------------------------|-----------------|----------------------|---------------------|--------------------|----------------------|----------------|--|
| LDP1 | Nitrogen dioxide - diesel | mg/m3 | Continuous | 0.0 | 0.0 | 90.0 | 5/06/2017 | No diesel used during the month |
| LDP1 | Nitrogen dioxide - gas | mg/m3 | Continuous | 0.0 | 0.0 | 60.0 | 5/06/2017 | No operation during the month |
| LDP2 | Nitrogen dioxide - diesel | mg/m3 | Continuous | 0.0 | 0.0 | 90.0 | 5/06/2017 | No diesel used during the month |
| LDP2 | Nitrogen dioxide - gas | mg/m3 | Continuous | 0.0 | 0.0 | 60.0 | 5/06/2017 | Steady load did not exceed 1hr service time during the month |
| LDP3 | Nitrogen dioxide - diesel | mg/m3 | Continuous | 0.0 | 0.0 | 90.0 | 5/06/2017 | No diesel used during the month |
| LDP3 | Nitrogen dioxide - gas | mg/m3 | Continuous | 0.0 | 0.0 | 60.0 | 5/06/2017 | Steady load did not exceed 1hr service time during the month |
| LDP4 | Nitrogen dioxide - diesel | mg/m3 | Continuous | 0.0 | 0.0 | 90.0 | 5/06/2017 | No diesel used during the month |
| LDP4 | Nitrogen dioxide - gas | mg/m3 | Continuous | 0.0 | 0.0 | 60.0 | 5/06/2017 | Steady load did not exceed 1hr service time during the month |

Correction Log

| Licensed Monitoring Point Code | Pollutant | Unit of Measure | Monitoring Frequency | Mean Hourly Average | Max Hourly Average | 100 Percentile limit | Published Date | Reason for Correction |
|--------------------------------|-----------|-----------------|----------------------|---------------------|--------------------|----------------------|----------------|-----------------------|
| Original Data | | | | | | | | |
| Corrected Data | | | | | | | | |