

# Colongra Power Station Monthly Summary Report February 2017

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	28/07/2017	Steady load did not exceed 1hr service time during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	31.4	33.9	60.0	28/07/2017	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	28/07/2017	Steady load did not exceed 1hr service time during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	37.9	40.2	60.0	28/07/2017	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	56.2	56.9	90.0	28/07/2017	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	22.5	26.1	60.0	28/07/2017	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	53.3	55.1	90.0	28/07/2017	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	23.4	28.9	60.0	28/07/2017	

## Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
<b>Original Data</b>								
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	8/03/2017	
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	31.4	33.4	60.0	8/03/2017	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	8/03/2017	Upon reviewing data for the 2016/2017 financial year, it became apparent that periods of unstable operation were included in the original calculations for February 2017. These periods of unstable operation have been discarded from the February calculations shown above.
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	42.8	56.9	60.0	8/03/2017	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	56.0	56.0	90.0	8/03/2017	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	22.5	24.7	60.0	8/03/2017	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	52.2	52.2	90.0	8/03/2017	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	24.5	30.5	60.0	8/03/2017	