

Colongra Power Station Monthly Summary Report November 2018

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	3/12/2018	No diesel generation during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	0.0	0.0	60.0	3/12/2018	Normal operation did not exceed 1 hour during the month
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	3/12/2018	No generation during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	0.0	0.0	60.0	3/12/2018	No generation during the month
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	3/12/2018	No generation during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	0.0	0.0	60.0	3/12/2018	No generation during the month
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	0.0	0.0	90.0	3/12/2018	No generation during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	0.0	0.0	60.0	3/12/2018	No generation during the month

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
--------------------------------	-----------	-----------------	----------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data