

Colongra Power Station Monthly Summary Report March 2020

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	64	64	90.0	3/04/2020	Annual emissions test result, 1 hour average of 62 mg/m3
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	45	45	60.0	3/04/2020	Annual emissions test result, 1 hour average of 42 mg/m3
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	72	72	90.0	3/04/2020	Annual emissions test result, 1 hour average of 71 mg/m3
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	41	42	60.0	3/04/2020	Annual emissions test result, 1 hour average of 34 mg/m3
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	90.0	3/04/2020	No diesel generation during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	40	40	60.0	3/04/2020	Annual emissions test result, 1 hour average of 36 mg/m3
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	89	89	90.0	3/04/2020	Annual emissions test result, 1 hour average of 88 mg/m3
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	52	52	60.0	3/04/2020	Annual emissions test result, 1 hour average of 45 mg/m3

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data								
Corrected Data								