

Colongra Power Station Monthly Summary Report June 2020

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	90.0	3/07/2020	Normal operation did not exceed 1 hour during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	34	36	60.0	3/07/2020	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	70	73	90.0	3/07/2020	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	47	52	60.0	3/07/2020	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	76	81	90.0	3/07/2020	Annual emissions test result, 1 hour average of 77 mg/m3
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	0	0	60.0	3/07/2020	No generation during the month
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	90.0	3/07/2020	Normal operation did not exceed 1 hour during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	45	45	60.0	3/07/2020	

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data								
Corrected Data								