

Colongra Power Station Monthly Summary Report July 2020

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	3/08/2020	Normal operation did not exceed 1 hour during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	39	42	45	60.0	3/08/2020	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	3/08/2020	No diesel generation during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	42	48	54	60.0	3/08/2020	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	3/08/2020	Normal operation did not exceed 1 hour during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	35	38	41	60.0	3/08/2020	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	3/08/2020	Normal operation did not exceed 1 hour during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	38	43	46	60.0	3/08/2020	

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data									
Corrected Data									