

Colongra Power Station Monthly Summary Report August 2020

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	4/09/2020	Normal operation did not exceed 1 hour during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	0	0	0	60.0	4/09/2020	Normal operation did not exceed 1 hour during the month
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	4/09/2020	Normal operation did not exceed 1 hour during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	0	0	0	60.0	4/09/2020	No generation during the month
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	4/09/2020	Normal operation did not exceed 1 hour during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	0	0	0	60.0	4/09/2020	No generation during the month
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	4/09/2020	Normal operation did not exceed 1 hour during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	0	0	0	60.0	4/09/2020	No generation during the month

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data									
Corrected Data									