

Colongra Power Station Monthly Summary Report

December 2020

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	60	62	63	90.0	12/01/2021	
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	30	35	46	60.0	12/01/2021	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	72	73	74	90.0	12/01/2021	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	27	33	39	60.0	12/01/2021	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	59	62	65	90.0	12/01/2021	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	20	25	33	60.0	12/01/2021	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	71	79	83	90.0	12/01/2021	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	28	30	31	60.0	12/01/2021	

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
--------------------------------	-----------	-----------------	----------------------	--------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data