

Colongra Power Station Monthly Summary Report May 2021

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	10/06/2021	No diesel generation during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	44	48	52	60.0	10/06/2021	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	10/06/2021	No diesel generation during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	41	43	46	60.0	10/06/2021	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	10/06/2021	No diesel generation during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	29	35	41	60.0	10/06/2021	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	62	62	62	90.0	10/06/2021	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	39	41	44	60.0	10/06/2021	

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data									
Corrected Data									