

Colongra Power Station Monthly Summary Report February 2021

Licenced Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	69	69	69	90.0	9/03/2021	Annual emissions test result, 1 hour average of 79 mg/m3
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	40	40	40	60.0	9/03/2021	Annual emissions test result, 1 hour average of 43 mg/m3
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	73	73	73	90.0	26/07/2021	Annual emissions test result, 1 hour average of 76 mg/m3
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	30	33	35	60.0	9/03/2021	Annual emissions test result, 1 hour average of 22 mg/m3
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	76	76	76	90.0	9/03/2021	Annual emissions test result, 1 hour average of 86 mg/m3
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	30	30	30	60.0	9/03/2021	Annual emissions test result, 1 hour average of 27mg/m3
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	83	83	83	90.0	9/03/2021	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	39	39	39	60.0	26/07/2021	Annual emissions test result, 1 hour average of 40 mg/m3

Correction Log

Licenced Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data									
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	73	0	0	90.0	9/03/2021	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	40	39	39	60.0	9/03/2021	
Corrected Data									
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	73	73	73	90.0	26/07/2021	Input error
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	39	39	39	60.0	26/07/2021	Input error