

Colongra Power Station Monthly Summary Report July 2021

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	63	68	73	90.0	2/08/2021	
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	48	55	58	60.0	2/08/2021	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	66	70	74	90.0	2/08/2021	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	39	44	51	60.0	2/08/2021	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	67	69	71	90.0	2/08/2021	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	32	38	45	60.0	2/08/2021	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	70	72	74	90.0	2/08/2021	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	38	43	46	60.0	2/08/2021	

Sampling is undertaken in accordance with the CEM-2 methodology as contained in the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".
Environment Protection Licence 13036

[EPA Public Register](#)

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data									

Corrected Data									
-----------------------	--	--	--	--	--	--	--	--	--