

Colongra Power Station Monthly Summary Report November 2020

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	14/12/2020	Normal operation did not exceed 1 hour during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	33	39	57	60.0	14/12/2020	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	26/07/2021	Normal operation did not exceed 1 hour during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	39	39	39	60.0	26/07/2021	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	14/12/2020	Normal operation did not exceed 1 hour during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	27	29	31	60.0	14/12/2020	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	14/12/2020	Normal operation did not exceed 1 hour during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	25	29	36	60.0	14/12/2020	

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data									
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	75	75	75	90.0	14/02/2020	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	35	40	56	60.0	14/12/2020	
Corrected Data									
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	26/07/2021	Normal operation did not exceed 1 hour during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	39	39	39	60.0	26/07/2021	Error in calculation