

Colongra Power Station Monthly Summary Report November 2021

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	6/12/2021	Normal operation did not exceed 1 hour during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	36	38	38	60.0	6/12/2021	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	6/12/2021	Normal operation did not exceed 1 hour during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	27	27	27	60.0	6/12/2021	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	6/12/2021	Normal operation did not exceed 1 hour during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	28	28	28	60.0	6/12/2021	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	6/12/2021	No diesel generation during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	0	0	0	60.0	6/12/2021	Normal operation did not exceed 1 hour during the month

Sampling is undertaken in accordance with the CEM-2 methodology as contained in the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

[EPA Public Register](#)

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
--------------------------------	-----------	-----------------	----------------------	--------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data