

Colongra Power Station Monthly Summary Report February 2022

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	69	69	70	90.0	10/03/2022	
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	37	40	46	60.0	10/03/2022	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	70	70	70	90.0	10/03/2022	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	26	32	43	60.0	10/03/2022	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	10/03/2022	No generation during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	28	38	53	60.0	10/03/2022	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	75	75	75	90.0	10/03/2022	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	36	41	47	60.0	10/03/2022	

Sampling is undertaken in accordance with the CEM-2 methodology as contained in the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".
Environment Protection Licence 13036

[EPA Public Register](#)

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data									

Corrected Data									
-----------------------	--	--	--	--	--	--	--	--	--