

Colongra Power Station Monthly Summary Report

March 2022

| Licensed Monitoring Point Code | Pollutant | Unit of Measure | Monitoring Frequency | Min Hourly Average | Mean Hourly Average | Max Hourly Average | 100 Percentile limit | Published Date | Comment |
|--------------------------------|---------------------------|-----------------|----------------------|--------------------|---------------------|--------------------|----------------------|----------------|---------------------------------------|
| LDP1 | Nitrogen dioxide - diesel | mg/m3 | Continuous | 68 | 68 | 68 | 90.0 | 7/04/2022 | |
| LDP1 | Nitrogen dioxide - gas | mg/m3 | Continuous | 36 | 38 | 40 | 60.0 | 7/04/2022 | |
| LDP2 | Nitrogen dioxide - diesel | mg/m3 | Continuous | 73 | 73 | 73 | 90.0 | 7/04/2022 | |
| LDP2 | Nitrogen dioxide - gas | mg/m3 | Continuous | 27 | 32 | 37 | 60.0 | 7/04/2022 | |
| LDP3 | Nitrogen dioxide - diesel | mg/m3 | Continuous | 77 | 77 | 77 | 90.0 | 7/04/2022 | |
| LDP3 | Nitrogen dioxide - gas | mg/m3 | Continuous | 27 | 34 | 43 | 60.0 | 7/04/2022 | |
| LDP4 | Nitrogen dioxide - diesel | mg/m3 | Continuous | 0 | 0 | 0 | 90.0 | 7/04/2022 | No diesel generation during the month |
| LDP4 | Nitrogen dioxide - gas | mg/m3 | Continuous | 35 | 40 | 48 | 60.0 | 7/04/2022 | |

Sampling is undertaken in accordance with the CEM-2 methodology as contained in the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

[EPA Public Register](#)

| Licensed Monitoring Point Code | Pollutant | Unit of Measure | Monitoring Frequency | Min Hourly Average | Mean Hourly Average | Max Hourly Average | 100 Percentile limit | Published Date | Reason for Correction |
|--------------------------------|-----------|-----------------|----------------------|--------------------|---------------------|--------------------|----------------------|----------------|-----------------------|
| Original Data | | | | | | | | | |

| | | | | | | | | | |
|-----------------------|--|--|--|--|--|--|--|--|--|
| Corrected Data | | | | | | | | | |
|-----------------------|--|--|--|--|--|--|--|--|--|