

# Colongra Power Station Monthly Summary Report

## April 2022

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous		0	0	90.0	9/05/2022	Normal operation did not exceed 1 hour during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	33	39	47	60.0	9/05/2022	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous		0	0	90.0	9/05/2022	Normal operation did not exceed 1 hour during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	30	36	43	60.0	9/05/2022	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous		0	0	90.0	9/05/2022	Normal operation did not exceed 1 hour during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	29	36	48	60.0	9/05/2022	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	77	77	77	90.0	9/05/2022	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	34	40	46	60.0	9/05/2022	

Sampling is undertaken in accordance with the CEM-2 methodology as contained in the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

[EPA Public Register](#)

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
--------------------------------	-----------	-----------------	----------------------	--------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data