

Colongra Power Station Monthly Summary Report July 2022

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	61	61	61	90.0	11/08/2022	
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	34	44	59	60.0	11/08/2022	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	57	62	73	90.0	11/08/2022	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	32	39	46	60.0	11/08/2022	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	64	76	87	90.0	11/08/2022	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	29	35	54	60.0	11/08/2022	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	62	67	73	90.0	11/08/2022	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	23	46	53	60.0	11/08/2022	

Sampling is undertaken in accordance with the CEM-2 methodology as contained in the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".
Environment Protection Licence 13036

[EPA Public Register](#)

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data									

Corrected Data									
-----------------------	--	--	--	--	--	--	--	--	--