

Colongra Power Station Monthly Summary Report

June 2022

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	51	59	62	90.0	6/07/2022	
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	33	42	54	60.0	6/07/2022	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	59	122	189	90.0	6/07/2022	NEM under AEMO direction
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	32	41	50	60.0	6/07/2022	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	62	115	185	90.0	6/07/2022	NEM under AEMO direction
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	30	37	54	60.0	6/07/2022	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	73	79	84	90.0	6/07/2022	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	42	46	54	60.0	6/07/2022	

Sampling is undertaken in accordance with the CEM-2 methodology as contained in the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".
Environment Protection Licence 13036

[EPA Public Register](#)

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
--------------------------------	-----------	-----------------	----------------------	--------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data