

# Colongra Power Station Monthly Summary Report

## October 2022

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	7/11/2022	No diesel generation during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	36	37	37	60.0	7/11/2022	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	7/11/2022	No diesel generation during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	25	30	39	60.0	7/11/2022	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	7/11/2022	No diesel generation during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	32	34	37	60.0	7/11/2022	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	7/11/2022	No diesel generation during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	46	47	48	60.0	7/11/2022	

Sampling is undertaken in accordance with the CEM-2 methodology as contained in the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

[EPA Public Register](#)

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
<b>Original Data</b>									
<b>Corrected Data</b>									