

Colongra Power Station Monthly Summary Report September 2022

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	14/10/2022	No diesel generation during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	43	43	43	60.0	14/10/2022	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	14/10/2022	No diesel generation during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	0	0	0	60.0	14/10/2022	Normal operation did not exceed 1 hour during the month
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	14/10/2022	No diesel generation during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	0	0	0	60.0	14/10/2022	Normal operation did not exceed 1 hour during the month
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	73	73	73	90.0	14/10/2022	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	39	42	45	60.0	14/10/2022	

Sampling is undertaken in accordance with the CEM-2 methodology as contained in the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".
Environment Protection Licence 13036

[EPA Public Register](#)

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data									

Corrected Data

