

HEZ Power Station Annual Emissions Monitoring 2022

Environmental Protection Licence No:	21466
Licensee:	Snowy Hydro Limited
Licensee address:	PO Box 332 Cooma NSW 2630
Premises:	HEZ Power Station, 105 Bromage Road Abermain NSW 2326
Location description:	Bank Exhaust Stacks
Monitoring frequency and period	Annually between 25 November 2021 and 25 November 2022.
EPA identification number:	Points 1, 2 and 3 - Discharge to Air Emissions Monitoring
Link to NSW EPA Public Register	

The Emissions Testing report was issued on 22 August 2022.

Sample Location	Sample Date	Pollutant	Units of Measure	Number of times monitored during the period	Concentration Limits (mg/m ³)	Result (mg/m ³)	Exceedance (Yes/No)
EPA Point 1: Stack serving Engines 1-6	10 June 2022	Carbon Monoxide	mg/m ³	1	300	54	No
		Solid Particles	mg/m ³	1	10	3.4	No
		Nitrogen Oxides	mg/m ³	1	200	52	No
EPA Point 2: Stack serving Engines 7-12	9 June 2022	Carbon Monoxide	mg/m ³	1	300	52	No
		Solid Particles	mg/m ³	1	10	7.1	No
		Nitrogen Oxides	mg/m ³	1	200	30	No
EPA Point 3: Stack serving Engines 13-16	9 June 2022	Carbon Monoxide	mg/m ³	1	300	66	No
		Solid Particles	mg/m ³	1	10	3.8	No
		Nitrogen Oxides	mg/m ³	1	200	110	No

Monitoring Point Location Plan:

