

# Colongra Power Station Monthly Summary Report

## March 2022

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	68	68	68	90.0	7/04/2022	Annual emissions test result, 1 hour average of 84 mg/m3
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	36	38	40	60.0	7/04/2022	Annual emissions test result, 1 hour average of 49mg/m3
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	73	73	73	90.0	7/04/2022	Annual emissions test result, 1 hour average of 89 mg/m3
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	27	32	37	60.0	7/04/2022	Annual emissions test result, 1 hour average of 41 mg/m3
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	77	77	77	90.0	7/04/2022	Annual emissions test result, 1 hour average of 89 mg/m3
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	27	34	43	60.0	7/04/2022	Annual emissions test result, 1 hour average of 45 mg/m3
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	0	90.0	7/04/2022	No diesel generation during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	35	40	48	60.0	7/04/2022	

Sampling is undertaken in accordance with the CEM-2 methodology as contained in the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

[EPA Public Register](#)

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
--------------------------------	-----------	-----------------	----------------------	--------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data