

# Colongra Power Station Monthly Summary Report May 2022

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	49	57	70	90.0	12/06/2022	
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	30	39	49	60.0	12/06/2022	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	59	64	73	90.0	12/06/2022	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	24	33	43	60.0	12/06/2022	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	65	69	74	90.0	12/06/2022	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	28	36	57	60.0	12/06/2022	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	66	67	69	90.0	12/06/2022	Annual emissions test result, 1 hour average of 73 mg/m3
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	34	41	48	60.0	12/06/2022	Annual emissions test result, 1 hour average of 45 mg/m3

Sampling is undertaken in accordance with the CEM-2 methodology as contained in the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

[EPA Public Register](#)

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
--------------------------------	-----------	-----------------	----------------------	--------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data