Colongra Power Station Monthly Summary Report November 2022

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
I	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	12/12/2022	No diesel generation during the month
I	Nitrogen oxides - gas	mg/m3	Continuous	34	37	40	60.0	12/12/2022	
2	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	12/12/2022	No diesel generation during the month
2	Nitrogen oxides - gas	mg/m3	Continuous	30	35	43	60.0	12/12/2022	
3	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	12/12/2022	Normal operation did not exceed 1 hour during the month
3	Nitrogen oxides - gas	mg/m3	Continuous	0	0	0	60.0	12/12/2022	Normal operation did not exceed I hour during the month
4	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	12/12/2022	No diesel generation during the month
4	Nitrogen oxides - gas	mg/m3	Continuous	51	52	52	60.0	12/12/2022	

Sampling is undertaken in accordance with the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

Premises Details: Off Scenic Drive, Budgewoi NSW 2262

Sample Type and Location: Discharge to air emissions monitoring from gas turbine exhaust stacks

Link to EPA Public Register

Correction Log

EPA Sample Point	Pollutant	Unit of	Monitoring	Min	Mean	Max	100	Published	Reason for Correction	
Identification No.		Measure	Frequency	Hourly	Hourly	Hourly	Percentile	Date		
				Average	Average	Average	limit			
Original Data										

Corrected Data