

# Colongra Power Station Monthly Summary Report

## May 2023

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
1	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	13/06/2023	No diesel generation during the month
1	Nitrogen oxides - gas	mg/m3	Continuous	53	53	54	60.0	13/06/2023	
2	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	13/06/2023	No diesel generation during the month
2	Nitrogen oxides - gas	mg/m3	Continuous	40	45	52	60.0	13/06/2023	
3	Nitrogen oxides - diesel	mg/m3	Continuous	76	79	82	90.0	13/06/2023	
3	Nitrogen oxides - gas	mg/m3	Continuous	34	41	47	60.0	13/06/2023	
4	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	13/06/2023	No diesel generation during the month
4	Nitrogen oxides - gas	mg/m3	Continuous	44	50	54	60.0	13/06/2023	

Sampling is undertaken in accordance with the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".  
Environment Protection Licence 13036

Premises Details: Off Scenic Drive, Budgewoi NSW 2262

Sample Type and Location: Discharge to air emissions monitoring from gas turbine exhaust stacks

[Link to EPA Public Register](#)

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
<b>Original Data</b>									

<b>Corrected Data</b>									
-----------------------	--	--	--	--	--	--	--	--	--