

## HEZ Power Station Annual Emissions Monitoring 2023

<b>Environmental Protection Licence No:</b>	21466
<b>Licensee:</b>	Snowy Hydro Limited
<b>Licensee address:</b>	PO Box 332 Cooma NSW 2630
<b>Premises:</b>	HEZ Power Station, 105 Bromage Road Abermain NSW 2326
<b>Location description:</b>	Bank Exhaust Stacks
<b>Monitoring frequency and period</b>	Annually between 25 November 2022 and 25 November 2023.
<b>EPA identification number:</b>	Points 1, 2 and 3 - Discharge to Air Emissions Monitoring
Link to <a href="#">NSW EPA Public Register</a>	

The Emissions Testing report was issued on 10 July 2023.

Sample Location	Sample Date	Pollutant	Units of Measure	Number of times monitored during the period	Concentration Limits (mg/m <sup>3</sup> )	Result (mg/m <sup>3</sup> )	Exceedance (Yes/No)
<b>EPA Point 1:</b> Stack serving Engines 1-6	6 June 2023	Carbon Monoxide	mg/m <sup>3</sup>	1	300	58	No
		Solid Particles	mg/m <sup>3</sup>	1	10	6.9	No
		Nitrogen Oxides	mg/m <sup>3</sup>	1	200	42	No
<b>EPA Point 2:</b> Stack serving Engines 7-12	6 June 2023	Carbon Monoxide	mg/m <sup>3</sup>	1	300	39	No
		Solid Particles	mg/m <sup>3</sup>	1	10	6.4	No
		Nitrogen Oxides	mg/m <sup>3</sup>	1	200	36	No
<b>EPA Point 3:</b> Stack serving Engines 13-16	7 June 2023	Carbon Monoxide	mg/m <sup>3</sup>	1	300	45	No
		Solid Particles	mg/m <sup>3</sup>	1	10	9.4	No
		Nitrogen Oxides	mg/m <sup>3</sup>	1	200	47	No

### Monitoring Point Location Plan:

