

Colongra Power Station Monthly Summary Report August 2023

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
1	Nitrogen oxides - diesel	mg/m3	Continuous		0	0	90.0	11/09/2023	Normal operation did not exceed 1 hour during the month
1	Nitrogen oxides - gas	mg/m3	Continuous		0	0	60.0	11/09/2023	No generation during the month
2	Nitrogen oxides - diesel	mg/m3	Continuous		0	0	90.0	11/09/2023	Normal operation did not exceed 1 hour during the month
2	Nitrogen oxides - gas	mg/m3	Continuous	47	48	48	60.0	11/09/2023	
3	Nitrogen oxides - diesel	mg/m3	Continuous		0	0	90.0	11/09/2023	Normal operation did not exceed 1 hour during the month
3	Nitrogen oxides - gas	mg/m3	Continuous	39	42	43	60.0	11/09/2023	
4	Nitrogen oxides - diesel	mg/m3	Continuous		0	0	90.0	11/09/2023	Normal operation did not exceed 1 hour during the month
4	Nitrogen oxides - gas	mg/m3	Continuous		0	0	60.0	11/09/2023	Normal operation did not exceed 1 hour during the month

Sampling is undertaken in accordance with the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

Premises Details: Off Scenic Drive, Budgewoi NSW 2262

Sample Type and Location: Discharge to air emissions monitoring from gas turbine exhaust stacks

[Link to EPA Public Register](#)

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
Original Data									

Corrected Data									
-----------------------	--	--	--	--	--	--	--	--	--