## Colongra Power Station Monthly Summary Report September 2023

EPA Sample Point	Pollutant	Unit of	Monitoring	Min	Mean	Max	100	Published	Comment
Identification No.		Measure	Frequency	Hourly	Hourly	Hourly	Percentile	Date	
				Average	Average	Average	limit		
I	Nitrogen oxides - diesel	mg/m3	Continuous		0	0	90.0	5/10/2023	No diesel generation during the month
I	Nitrogen oxides - gas	mg/m3	Continuous		0	0	60.0	5/10/2023	Normal operation did not exceed 1 hour during the month
2	Nitrogen oxides - diesel	mg/m3	Continuous		0	0	90.0	5/10/2023	No diesel generation during the month
2	Nitrogen oxides - gas	mg/m3	Continuous		0	0	60.0	5/10/2023	Normal operation did not exceed 1 hour during the month
3	Nitrogen oxides - diesel	mg/m3	Continuous		0	0	90.0	5/10/2023	No diesel generation during the month
3	Nitrogen oxides - gas	mg/m3	Continuous	41	41	41	60.0	5/10/2023	
4	Nitrogen oxides - diesel	mg/m3	Continuous		0	0	90.0	5/10/2023	No diesel generation during the month
4	Nitrogen oxides - gas	mg/m3	Continuous	50	50	50	60.0	5/10/2023	

Sampling is undertaken in accordance with the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW". Environment Protection Licence 13036

Premises Details: Off Scenic Drive, Budgewoi NSW 2262

Sample Type and Location: Discharge to air emissions monitoring from gas turbine exhaust stacks

## Link to EPA Public Register

<b>EPA Sample Point</b>	Pollutant	Unit of	Monitoring	Min	Mean	Max	100	Published	Reason for Correction	
Identification No.		Measure	Frequency	Hourly	Hourly	Hourly	Percentile	Date		
				Average	Average	Average	limit			
	Original Data									

## **Corrected Data**