

Colongra Power Station Monthly Summary Report November 2023

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
1	Nitrogen oxides - diesel	mg/m3	Continuous		0	0	90.0	4/12/2023	Normal operation did not exceed 1 hour during the month
1	Nitrogen oxides - gas	mg/m3	Continuous	41	44	48	60.0	4/12/2023	
2	Nitrogen oxides - diesel	mg/m3	Continuous		0	0	90.0	4/12/2023	Normal operation did not exceed 1 hour during the month
2	Nitrogen oxides - gas	mg/m3	Continuous	33	38	57	60.0	4/12/2023	
3	Nitrogen oxides - diesel	mg/m3	Continuous		0	0	90.0	4/12/2023	No generation during the month
3	Nitrogen oxides - gas	mg/m3	Continuous		0	0	60.0	4/12/2023	No generation during the month
4	Nitrogen oxides - diesel	mg/m3	Continuous		0	0	90.0	4/12/2023	Normal operation did not exceed 1 hour during the month
4	Nitrogen oxides - gas	mg/m3	Continuous	40	46	51	60.0	4/12/2023	

Sampling is undertaken in accordance with the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

Premises Details: Off Scenic Drive, Budgewoi NSW 2262

Sample Type and Location: Discharge to air emissions monitoring from gas turbine exhaust stacks

[Link to EPA Public Register](#)

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
-------------------------------------	-----------	-----------------	----------------------	--------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data