

Colongra Power Station Monthly Summary Report

January 2024

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
1	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	12/02/2024	Normal operation did not exceed 1 hour during the month
1	Nitrogen oxides - gas	mg/m3	Continuous	46	46	46	60.0	12/02/2024	
2	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	12/02/2024	Normal operation did not exceed 1 hour during the month
2	Nitrogen oxides - gas	mg/m3	Continuous	36	39	44	60.0	12/02/2024	
3	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	12/02/2024	No diesel generation during the month
3	Nitrogen oxides - gas	mg/m3	Continuous	38	39	42	60.0	12/02/2024	
4	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	12/02/2024	No diesel generation during the month
4	Nitrogen oxides - gas	mg/m3	Continuous	38	42	48	60.0	12/02/2024	

Sampling is undertaken in accordance with the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

Premises Details: Off Scenic Drive, Budgewoi NSW 2262

Sample Type and Location: Discharge to air emissions monitoring from gas turbine exhaust stacks

[Link to EPA Public Register](#)

Correction Log

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
-------------------------------------	-----------	-----------------	----------------------	--------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data