

Colongra Power Station Monthly Summary Report December 2023

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
1	Nitrogen oxides - diesel	mg/m3	Continuous	44	74	119.8	90.0	12/01/2024	Variation to EPL limit for planned maintenance combustion tuning of unit C1
1	Nitrogen oxides - gas	mg/m3	Continuous	0	0	0	60.0	12/01/2024	Normal operation did not exceed 1 hour during the month
2	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	12/01/2024	No diesel generation during the month
2	Nitrogen oxides - gas	mg/m3	Continuous	34	37	39	60.0	12/01/2024	
3	Nitrogen oxides - diesel	mg/m3	Continuous	108	119	137	90.0	12/01/2024	Critical tuning works (non-commercial operation) temporary exceedance of emission limits reported to EPA
3	Nitrogen oxides - gas	mg/m3	Continuous	62	83	114	60.0	12/01/2024	
4	Nitrogen oxides - diesel	mg/m3	Continuous	69	71	74	90.0	12/01/2024	
4	Nitrogen oxides - gas	mg/m3	Continuous	42	44	46	60.0	12/01/2024	

Sampling is undertaken in accordance with the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

Premises Details: Off Scenic Drive, Budgewoi NSW 2262

Sample Type and Location: Discharge to air emissions monitoring from gas turbine exhaust stacks

[Link to EPA Public Register](#)

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
-------------------------------------	-----------	-----------------	----------------------	--------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data