

# Colongra Power Station Monthly Summary Report

## May 2024

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
1	Nitrogen oxides - diesel	mg/m3	Continuous	67	67	67	90.0	12/06/2024	
1	Nitrogen oxides - gas	mg/m3	Continuous	0	0	0	60.0	12/06/2024	No generation during the month
2	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	12/06/2024	No generation during the month
2	Nitrogen oxides - gas	mg/m3	Continuous	47	50	52	60.0	12/06/2024	
3	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	12/06/2024	No generation during the month
3	Nitrogen oxides - gas	mg/m3	Continuous	41	47	58	60.0	12/06/2024	
4	Nitrogen oxides - diesel	mg/m3	Continuous	0	0	0	90.0	12/06/2024	No generation during the month
4	Nitrogen oxides - gas	mg/m3	Continuous	49	55	58	60.0	12/06/2024	

Sampling is undertaken in accordance with the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

Premises Details: Off Scenic Drive, Budgewoi NSW 2262

Sample Type and Location: Discharge to air emissions monitoring from gas turbine exhaust stacks

[Link to EPA Public Register](#)

### Correction Log

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
-------------------------------------	-----------	-----------------	----------------------	--------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data