

Colongra Power Station Monthly Summary Report

June 2024

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
1	Nitrogen oxides - diesel	mg/m3	Continuous	66	66	67	90	12/07/2024	
1	Nitrogen oxides - gas	mg/m3	Continuous	0	0	0	60	12/07/2024	No generation during the month
2	Nitrogen oxides - diesel	mg/m3	Continuous	71	72	73	90	12/07/2024	
2	Nitrogen oxides - gas	mg/m3	Continuous	43	52	58	60	12/07/2024	
3	Nitrogen oxides - diesel	mg/m3	Continuous	69	71	72	90	12/07/2024	
3	Nitrogen oxides - gas	mg/m3	Continuous	43	49	58	60	12/07/2024	
4	Nitrogen oxides - diesel	mg/m3	Continuous	77	79	81	90	12/07/2024	
4	Nitrogen oxides - gas	mg/m3	Continuous	50	55	61	60	12/07/2024	Notified to the EPA

Sampling is undertaken in accordance with the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

Premises Details: Off Scenic Drive, Budgewoi NSW 2262

Sample Type and Location: Discharge to air emissions monitoring from gas turbine exhaust stacks

[Link to EPA Public Register](#)

Correction Log

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
-------------------------------------	-----------	-----------------	----------------------	--------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data