

Colongra Power Station Monthly Summary Report November 2024

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
1	Nitrogen oxides - diesel	mg/m3	Continuous	53	58	68	90.0	10/12/2024	
1	Nitrogen oxides - gas	mg/m3	Continuous	0	0	0	60.0	10/12/2024	No generation during the month
2	Nitrogen oxides - diesel	mg/m3	Continuous	67	68	69	90.0	10/12/2024	
2	Nitrogen oxides - gas	mg/m3	Continuous	32	36	44	60.0	10/12/2024	
3	Nitrogen oxides - diesel	mg/m3	Continuous	55	57	60	90.0	10/12/2024	
3	Nitrogen oxides - gas	mg/m3	Continuous	28	35	41	60.0	10/12/2024	
4	Nitrogen oxides - diesel	mg/m3	Continuous	63	68	76	90.0	10/12/2024	
4	Nitrogen oxides - gas	mg/m3	Continuous	34	42	49	60.0	10/12/2024	

Sampling is undertaken in accordance with the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

Environment Protection Licence 13036

Premises Details: Off Scenic Drive, Budgewoi NSW 2262

Sample Type and Location: Discharge to air emissions monitoring from gas turbine exhaust stacks

[Link to EPA Public Register](#)

Correction Log

EPA Sample Point Identification No.	Pollutant	Unit of Measure	Monitoring Frequency	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
-------------------------------------	-----------	-----------------	----------------------	--------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data