





Hunter Power Project - Air Monitoring Summary

Licensee: Snowy Hydro Limited
Address: Hart Rd, Loxford, NSW, 2327
EPL Number: 21627

Date Sampled	Date Obtained	Date Published	Fuel	EPA ID No. 1 - Monthly Averages						
				Nitrous Oxides	Moisture	Carbon Monoxide	Oxygen	Temperature	Velocity	Flow Rate
				mg/Nm3	%	%	%	deg C	m/s	m3/s
21-31/07/2025	20/8/2025	21/08/2025	Gas	44.97	5.91	1747.40	14.58	508.67	27.77	490.89



Where: NT indicates that parameter was not tested
NR indicates that data was not recorded

