

## Hunter Power Station Monthly EPL Monitoring Data Report May 2026

### Premises Details

**Environment Protection Licence No.** 21627  
**Licencee's Name** Snowy Hydro Limited  
**Premises Name** Hunter Power Station  
**Premises Address** 1 Hart Road, Loxford NSW 2326

**Link to EPA Public Register** [Click Here](#)

**Link to EPL21627 on EPA Public Register** [Click Here](#)

### Summary of Air Emission Monitoring Data - Unit 1

Monitoring Location / EPA ID No.	Pollutant	Unit of Measure	Monitoring Frequency	Monitoring Period	Date Data Obtained	Published Date	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 %ile Concentration Limit	Comment
1	Nitrogen Oxides (Gas Generation)	mg/m <sup>3</sup>	Continuous	May 2026	5 Jun 2026	5 Jun 2026	41.5	44.6	47.7	103	Commissioning activities occurred during the month. Special Condition E2.4 specifies emission limits for commissioning activity
1	Carbon Monoxide (Gas Generation)	mg/m <sup>3</sup>	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.8	1.6	2.1	12.5	Commissioning activities occurred during the month. Special Condition E2.4 specifies emission limits for commissioning activity
1	Nitrogen Oxides (Diesel Generation)	mg/m <sup>3</sup>	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.0	0.0	0.0	123	No diesel commissioning activities during the month
1	Carbon Monoxide (Diesel Generation)	mg/m <sup>3</sup>	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.0	0.0	0.0	63	No commissioning activities during the month
1	Moisture	%	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.6	2.1	33.0	N/A	
1	Oxygen	%	Continuous	May 2026	5 Jun 2026	5 Jun 2026	10.7	20.9	21.3	N/A	
1	Temperature	°C	Continuous	May 2026	5 Jun 2026	5 Jun 2026	11.8	26.5	612.0	N/A	
1	Velocity	m/s	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.1	0.3	44.7	N/A	
1	Volumetric Flowrate	m <sup>3</sup> /s	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.4	6.9	992.7	N/A	

### Summary of Air Emission Monitoring Data - Unit 2

Monitoring Location / EPA ID No.	Pollutant	Unit of Measure	Monitoring Frequency	Monitoring Period	Date Data Obtained	Published Date	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 %ile Concentration Limit	Comment
2	Nitrogen Oxides (Gas Generation)	mg/m <sup>3</sup>	Continuous	May 2026	5 Jun 2026	5 Jun 2026	50.0	50.0	50.0	103	Commissioning activities occurred over a single hour block during the month. Special Condition E2.4 specifies emission limits for commissioning activity
2	Carbon Monoxide (Gas Generation)	mg/m <sup>3</sup>	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.3	0.3	0.3	12.5	Commissioning activities occurred during the month. Special Condition E2.4 specifies emission limits for commissioning activity
2	Nitrogen Oxides (Diesel Generation)	mg/m <sup>3</sup>	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.0	0.0	0.0	123	No diesel commissioning activities during the month
2	Carbon Monoxide (Diesel Generation)	mg/m <sup>3</sup>	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.0	0.0	0.0	63	No commissioning activities during the month
2	Moisture	%	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.0	2.6	30.1	N/A	
2	Oxygen	%	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.0	21.2	25.8	N/A	
2	Temperature	°C	Continuous	May 2026	5 Jun 2026	5 Jun 2026	10.9	26.8	627.4	N/A	
2	Velocity	m/s	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.1	0.3	45.5	N/A	
2	Volumetric Flowrate	m <sup>3</sup> /s	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.4	4.5	1073.0	N/A	

#### Notes on air emission monitoring data summaries for Units 1 and 2:

- Sampling is undertaken in accordance with the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW", US EPA Procedure 1, Method CEM-2 (Nitrogen Oxides), & CEM-4 (Carbon Monoxide)
- Sample Type and Location: Discharges to air from turbine exhaust stacks
- The 100%ile Concentration Limit for Nitrogen Oxides and Carbon Monoxide are specified as 'Hourly Average' in EPL21627. As per the averaging periods specified in the POEO (Clean Air) Regulation 2022, the averaging period for Nitrogen Oxides is a '1 hour block', and for Carbon Monoxide it is '1 hour rolling'.
- For the purpose of the licence, Nitrogen Oxides means: Nitrogen Dioxide (NO<sub>2</sub>) or Nitric Oxide (NO) or both, as NO<sub>2</sub> equivalent.
- mg/m<sup>3</sup> refers to milligrams per cubic metre
- Data presented for Nitrogen Oxides represents periods of generation only

**Summary of Surface Water Discharge Monitoring Data**

Monitoring Location / EPA ID No.	Pollutant	Unit of Measure	Monitoring Frequency	Date Sampled	Date Data Obtained	Published Date	Result	EPL Concentration Limit	Comment
3	Oil and Grease	mg/L	Monthly during discharge	4 May 2026	18 May 2026	5 Jun 2026	<5	N/A	
3	pH	pH	Monthly during discharge	4 May 2026	18 May 2026	5 Jun 2026	8.1	N/A	
3	Total Solids	mg/L	Monthly during discharge	4 May 2026	18 May 2026	5 Jun 2026	910	N/A	
3	Total Suspended Solids	mg/L	Monthly during discharge	4 May 2026	18 May 2026	5 Jun 2026	<5	N/A	
3	Turbidity	NTU	Monthly during discharge	4 May 2026	18 May 2026	5 Jun 2026	3.3	N/A	

**Notes on surface water discharge monitoring summary:**

- The sampling method for surface water quality is a grab sample in accordance with Condition M2.5 of EPL21627.
- Sample Type and Location: surface water discharges from the stormwater discharge outlet.
- mg/L refers to milligrams per litre, NTU refers to nephelometric turbidity units

**Summary of Meteorological Monitoring Data**

Monitoring Location / EPA ID No.	Pollutant	Unit of Measure	Monitoring Frequency	Monitoring Period	Date Data Obtained	Published Date	Min	Average	Max	Comment
4	Temperature at 2 metres	degrees Celcius	Continuous	May 2026	5 Jun 2026	5 Jun 2026	5.2	16.7	27.0	
4	Wind Direction at 10 metres	degrees Celcius	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.0	203.5	359.9	
4	Wind Speed at 10 metres	metres per second	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.0	1.9	12.1	
4	Sigma Theta	degrees Celcius	Continuous	May 2026	5 Jun 2026	5 Jun 2026	1.2	13.7	80.9	
4	Rainfall	millimetres	Continuous	May 2026	5 Jun 2026	5 Jun 2026	0.0	2.1	32.4	
4	Relative Humidity	percent humidity	Continuous	May 2026	5 Jun 2026	5 Jun 2026	22.7	80.5	98.7	

**Notes on meteorological monitoring summary:**

- Sampling is undertaken in accordance with the "Table of AM-coded methods for ambient air monitoring", AM-2 (Wind Speed & Direction, Sigma Theta), and AM-4 (All parameters).
- Sample Type and Location: Meteorological Monitoring from the onsite weather station
- Data presented is the monthly average for each parameter, except rainfall which is daily.

**Correction Log**

Monitoring Location / EPA ID No.	Pollutant	Unit of Measure	Monitoring Frequency	Monitoring Period	Original Data	Date Originally Published	Corrected Data	Date Corrected	Reason for Correction

**Aerial Image and Monitoring Locations** (Note: Site boundaries and monitoring locations displayed are indicative only.)

