

Colongra Power Station Monthly Summary Report June 2026

Premises Details

Environment Protection Licence No. 13036
Licencee's Name Snowy Hydro Limited
Premises Name Colongra Power Station
Premises Address Off Scenic Drive, Budgewoi NSW 2262
Link to EPA Public Register [Click Here](#)
Link to EPL13036 on EPA Public Register [Click Here](#)

Summary of Monitoring Data

Monitoring Location / EPA ID No.	Pollutant	Unit of Measure	Monitoring Frequency	Monitoring Period	Date Data Obtained	Published Date	Min Hourly Average	Mean Hourly Average	Max Hourly Average	100 %ile Concentration Limit	Comment
1	Nitrogen Oxides - Gas	mg/m ³	Continuous during discharge	June 2026	15 Jul 2026	15 Jul 2026	0.0	0.0	0.0	60	Gas generation did not exceed a one hour block during the month
1	Nitrogen Oxides - Diesel	mg/m ³	Continuous during discharge	June 2026	15 Jul 2026	15 Jul 2026	0.0	0.0	0.0	90	No diesel generation during the month
2	Nitrogen Oxides - Gas	mg/m ³	Continuous during discharge	June 2026	15 Jul 2026	15 Jul 2026	0.0	0.0	0.0	60	Gas generation did not exceed a one hour block during the month
2	Nitrogen Oxides - Diesel	mg/m ³	Continuous during discharge	June 2026	15 Jul 2026	15 Jul 2026	0.0	0.0	0.0	90	No diesel generation during the month
3	Nitrogen Oxides - Gas	mg/m ³	Continuous during discharge	June 2026	15 Jul 2026	15 Jul 2026	0.0	0.0	0.0	60	Gas generation did not exceed a one hour block during the month
3	Nitrogen Oxides - Diesel	mg/m ³	Continuous during discharge	June 2026	15 Jul 2026	15 Jul 2026	0.0	0.0	0.0	90	No diesel generation during the month
4	Nitrogen Oxides - Gas	mg/m ³	Continuous during discharge	June 2026	15 Jul 2026	15 Jul 2026	0.0	0.0	0.0	60	Gas generation did not exceed a one hour block during the month
4	Nitrogen Oxides - Diesel	mg/m ³	Continuous during discharge	June 2026	15 Jul 2026	15 Jul 2026	0.0	0.0	0.0	90	No diesel generation during the month

Notes on data summary:

- Sampling is undertaken in accordance with the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW", Method CEM-2
- Sample Type and Location: Discharge to air emissions monitoring from turbine exhaust stacks
- For the purpose of the licence, Nitrogen Oxides means: Nitrogen Dioxide (NO₂) or Nitric Oxide (NO) or both, as NO₂ equivalent.
- mg/m³ refers to milligrams per metre cubed

Correction Log

Monitoring Location / EPA ID No.	Pollutant	Unit of Measure	Monitoring Frequency	Monitoring Period	Original Data	Date Originally Published	Corrected Data	Date Corrected	Reason for Correction

Aerial Image and Monitoring Locations

Note: Site boundaries and monitoring locations displayed are indicative only.

