

Colongra Power Station Monthly Summary Report February 2015

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	5/03/2015	No operation during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	5/03/2015	No operation during the month
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	5/03/2015	No operation during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	5/03/2015	No operation during the month
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	5/03/2015	No operation during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	5/03/2015	No operation during the month
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	5/03/2015	No operation during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	5/03/2015	Steady load did not exceed 1hr service time during the month