

## Colongra Power Station Monthly Summary Report March 2015

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - gas	mg/m3	Yearly		32.0	60.0	14/04/2015	No diesel used during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	39.3	39.3	60.0	14/04/2015	No diesel used during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Yearly		38.0	60.0	14/04/2015	No diesel used during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	28.4	28.4	60.0	14/04/2015	No diesel used during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Yearly		33.0	60.0	14/04/2015	No diesel used during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	27.4	27.4	60.0	14/04/2015	No diesel used during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Yearly		33.0	60.0	14/04/2015	No diesel used during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	35.4	35.4	60.0	14/04/2015	No diesel used during the month