Colongra Power Station Monthly Summary Report
September 2015

Licenced Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	15/10/2015	
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	27.7	27.7	60.0	15/10/2015	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	15/10/2015	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	39.8	40.0	60.0	15/10/2015	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	15/10/2015	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	40.2	52.3	60.0	15/10/2015	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	15/10/2015	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	15/10/2015	Normal operation did not exceed one hour

Correction Log

Licenced Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	29.7	29.7	60.0	15/10/2015	Data connection and calculation did not pick up all data
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	40.6	42.0	60.0	15/10/2015	Data connection and calculation did not pick up all data
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	29.4	31.7	60.0	15/10/2015	Data connection and calculation did not pick up all data

Corrected Data								
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	27.7	27.7	60.0	12/08/2016	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	39.8	40.0	60.0	12/08/2016	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	40.2	52.3	60.0	12/08/2016	