

Colongra Power Station Monthly Summary Report November 2015

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	15/10/2015	No diesel used during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	15/10/2015	No operation during the month
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	48.7	48.7	90.0	15/10/2015	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	41.7	52.7	60.0	15/10/2015	Excluding period of instrument downtime
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	15/10/2015	No diesel used during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	40.2	52.3	60.0	15/10/2015	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	15/10/2015	No diesel used during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	32.8	34.9	60.0	15/10/2015	

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	44.8		60.0	15/10/2015	Data connection and calculation did not pick up all data
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous		33.4	60.0	15/10/2015	Data connection and calculation did not pick up all data

Corrected Data

LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	41.7		60.0	12/08/2016	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous		34.9	60.0	12/08/2016	