

Colongra Power Station Monthly Summary Report

December 2015

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	6/01/2015	
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	6/01/2015	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	6/01/2015	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	6/01/2015	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	6/01/2015	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	22.7	27.5	60.0	6/01/2015	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	6/01/2015	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	28.5	32.1	60.0	6/01/2015	

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous		22.7	60.0	6/01/2015	Data connection and calculation did not pick up all data
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	30.6	32.7	60.0	6/01/2015	Data connection and calculation did not pick up all data
Corrected Data								
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous		27.5	60.0	12/08/2016	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	28.5	32.1	60.0	12/08/2016	