

# Colongra Power Station Monthly Summary Report

## January 2016

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	1/02/2016	
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	1/02/2016	No operation during the month
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	1/02/2016	
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	45.0	54.5	60.0	1/02/2016	
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	1/02/2016	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	22.4	28.7	60.0	1/02/2016	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous			90.0	1/02/2016	
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous			60.0	1/02/2016	No operation during the month

### Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous		46.7	60.0	1/02/2016	Data connection and calculation did not pick up all data
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous		22.6	60.0	1/02/2016	Data connection and calculation did not pick up all data
<b>Corrected Data</b>								
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous		54.5	60.0	12/08/2016	
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous		28.7	60.0	12/08/2016	